

Illinois Commerce Commission**Pipeline Safety****Pipeline Safety Report****Inspection #: 2015-P-00397**

Operator: AMEREN ILLINOIS COMPANY	Operator ID#: 32513
Exit Meeting Contact: Kevin Glaspy	Total Man Days: 6
Pipeline Safety Representative(s): Donald Hankins, Bryan Pemble	
Company Representative to Receive Report: Michael Fuller	<u>Emailed Date:</u>
Company Representative's Email Address: mfuller2@ameren.com	12/22/2015

Inspection Summary

Inspection Type	Location	ICC Analyst	Inspection Unit(s)	Man Day(s)	Inspection Date(s)	Contact(s)
Design Testing and Construction	Decatur	Donald Hankins, Bryan Pemble	Decatur	6	12/10/2015, 12/8/2015, 12/9/2015	Kevin Glaspy

Statement of Activities

On December 8, 9, & 10, 2015, staff conducted a construction audit at Ameren Illinois, in Decatur, Illinois, to determine compliance with applicable IL Adm. Codes and the Code of Federal Regulations adopted via IL Adm. Part 590.

On December 8, 2015, Ameren Illinois was installing a new service line to 6342 Autumn Ridge. The service line was a 1 inch Driscoplex plastic pipe. The Ameren crew inserted the 1 inch pipe through a 2 inch plastic casing, with the casing being 250 feet long.

On December 9, 2015, an Ameren crew exposed an electric line, and telephone cable, and a cable TV line, and then Ameren made a 50 foot bore using a hammer head mole.

On December 10, 2015, Ameren Illinois made the connection of the service line to the gas main using electro fusion fittings, and an electro fusion tapping tee. The service line was air tested to 101 pounds for 10 minutes, with no leaks being found.

Exit Statement**INSPECTION FINDINGS****Design Testing and Construction****Issues(s) Found:**

[NO ISSUES FOUND]

Notice Of Amendment(s) Found:

[NO NOAS FOUND]

Notice Of Violation(s) Found:

[NO NOPVS FOUND]

PAST INSPECTION FINDINGS

**Illinois Commerce Commission
Pipeline Safety
Pipeline Safety Report**

Inspection #: 2015-P-00397

Issue(s) Corrected:

[NO ISSUES CORRECTED]

Notice Of Amendment(s) Corrected:

[NO NOAS CORRECTED]

Notice of Violations(s) Corrected:

[NO NOPVS CORRECTED]